

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

To,

Principal Sahibzada Baba Fateh Singh Public School Guru Ka Bagh, Tehsil Ajnala, Amritsar
Sahibzada Baba Fateh Singh Public School Guru Ka Bagh, Tehsil Ajnala, Amritsar

No.: RWTLASR/2324/00059 Dated : 18/05/2023

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SBFSPS/23-24/75 Dated: 11/05/2023

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 12/05/2023. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Amritsar

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab, Amritsar



IC-9815

TEST REPORT

Name & Address of Customer : Principal Sahibzada Baba Fateh Singh Public School Guru Ka Bagh, Tehsil Ajnala, Amritsar Sahibzada Baba Fateh Singh Public School Guru Ka Bagh, Tehsil Ajnala, Amritsar	Customer Reference No.	No : SBFSPS/23-24/75 Dated : 11/05/2023
	Sample Submitted by	S. Pushapinder Singh
	Date of Sample Receipt	12/05/2023
	Analysis Starting Date	12/05/2023
	Analysis completion Date	13/05/2023

Discipline : Chemical Testing		Group: Water	
ULR No.:	TC98152300000253F	Sample Type :	Water
Test Report No.:	RWTLASR/2324/00059	Date of Issue :	18/05/2023
Registration no.:	RWTLASR/REG2324/01251	Condition of Sample :	Unsealed
Collection Point:	Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Ajnala(S/pump 300 ft) / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Amritsar
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	6.83	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-1993) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	TDS	58	500	2000	mg/l	IS 3025 (Part 16-1984) Gravimetric Method
5	Turbidity	0.29	1	5	NTU	IS 3025 (Part 10-1984) Nephelometric Method
6	Alkalinity	68	200	600	mg/l	IS 3025 (Part 23-1986) Indicator Method
7	Hardness	44	200	600	mg/l	IS 3025 (Part 21- 2019) EDTA Method
8	Calcium	9.61	75	200	mg/l	IS 3025 (Part 40-1991) EDTA Titrimetric Method
9	Magnesium	4.86	30	100	mg/l	APHA (23rd Ed.2017) Method: 3500-Mg+2 B By Calculation Method
10	Chloride	9.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

- The results apply to the sample as received only.
- The sample will be destroyed after retention time unless otherwise specified specially.
- This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
- Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed), ND=Not Detected
- * Value not available or test not performed for this parameter.
- Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab, Amritsar

----- End of the Test Report -----

REGIONAL WATER TESTING LAB, AMRITSAR
New Golden Avenue, Opposite Dhobi Ghat, Near Jaura Phatak, Amritsar.
rwtlasr1@gmail.com

INVOICE

Bill No. : INV/2324/00123

Date. : 12/05/2023

To,


Principal Sahibzada Baba Fateh Singh Public School Guru Ka Bagh, Tehsil Ajnala, Amritsar
Sahibzada Baba Fateh Singh Public School Guru Ka Bagh, Tehsil Ajnala, Amritsar

Ref. : Letter No. SBFSPS/23-24/75 Dt. 11/05/2023

Sample Receiving No. RWTLASR/R2324/00123 Dt. 12/05/2023

Sr. No.	Name of Scheme / Source / Location	Nature of Sample	Category Name	Test Parameter	No. of Sample	Rate Per Parameter/ Set of Parameters	Net Amount
1	Ajnala(S/pump 300 ft)	Water	Private Schools	Basic Chemical : pH, Colour, Odour, TDS, Turbidity, Alkalinity, Hardness, Calcium, Magnesium, Chloride	1	129.00	129.00
Total							129.00
One Hundred Twenty Nine Only.							
Payment Mode : Cash			Payment Status : PAID		STR No. : SBFSPS/23-24/75 11/05/202		

Nqte:- * Discount applicable as per Government Notification Number : No 9284 & Date : 09/11/2021



Mr. Yadwinder Singh
Authorised Signatory